

PWS Ballistic Screen System

PWS Ltd, Evans Business Centre, Monckton Road, Wakefield, West Yorkshire, WF2 7AS

*Have provided samples of their **PWS Ballistic Screen System** product tested to FB4 Classification in accordance with the requirements and procedures set out within 'BS EN 1522:1999 Windows, Doors, Shutters and Blinds - Bullet Resistance - Requirements and Classification' by D.J. Goode and Associates Ltd (exclusions and caveats to the test standard apply, the test report must be read for details.)*

FB4 Classification

TESTED WITH: .44" Remington Magnum, Full metal jacket bullet, Flat Nose, Soft Core (Lead),
Velocity 440 m/sec \pm 10m/sec, Mass 15.6 grams \pm 0.1g
.357" Remington Magnum, Full metal jacket bullet, Coned Nose, Soft Core (Lead),
Velocity 430 m/sec \pm 10m/sec, Mass 10.2 grams \pm 0.1g

TEST DATE: 28th November 2016 & 01st August 2017

LOCATION: D.J. Goode and Associates Ltd, Enclosed Range, The Old Control Tower,
Lavenham Airfield, Alpheton, Suffolk, CO10 9BT

CLASSIFICATION: **FB4 Pass – "NS" No Spall**

GLAZING DETAIL: Hamilton Erskine – TSG BR4NS

Notes

1. The above summary must be read in conjunction with the test reports, **Protective Window Solutions Ltd – TS047/03R & TS067/01R**
2. This certificate shall not be reproduced, except in full, without the permission of DGA

Signed



David Robinson
Testing & Compliance Manager

On behalf of D.J. Goode and Associates Ltd

Date: 20/04/18



4621

Consulting Civil Engineers
D J Goode & Associates Ltd

Registered Office:
The Old Control Tower
Lavenham Airfield
Old Bury Road, Alpheton
Sudbury, Suffolk, CO10 9BT
Tel: 01284 827472
Email: p1@djgoode.co.uk

Company Reg. No. 4568964

Registered in England & Wales