

Protective Windows Solutions Ltd

National Window Films, Evans Business Centre, Monckton Road, Wakefield, West Yorkshire, WF2 7AS

Have had their PWS Ballistic Screen System product tested to FB3 Classification in accordance with the requirements and procedures set out within 'BS EN 1522:1999 Windows, Doors, Shutters and Blinds - Bullet Resistance - Requirements and Classification' by D.J. Goode and Associates Ltd (exclusions and caveats to the test standard apply, the test report must be read for details.)

FB3 Classification

TESTED WITH: .357" Remington Magnum, Full metal jacket bullet, Coned Nose, Soft Core (Lead)
Velocity 430 m/sec \pm 10m/sec, Mass 10.2 grams \pm 0.1g

TEST DATE: 28th November 2016

LOCATION: D.J. Goode and Associates Ltd, Enclosed Range, The Old Control Tower,
Lavenham Airfield, Alpheton, Suffolk, CO10 9BT

CLASSIFICATION: FB3 Pass – "NS" No Spall

GLAZING DETAIL: Hamilton Erskine – TSG BR4NS

Notes

1. The above summary must be read in conjunction with the letter test report, **Protective Window Solutions Ltd – TS047/03R**
2. This certificate shall not be reproduced, except in full, without the permission of DGA


Signed



David Robinson
Testing & Compliance Manager

On behalf of D.J. Goode and Associates Ltd

Date: 03/03/17



DGA



4621

Consulting Civil Engineers
D J Goode & Associates Ltd

Registered Office:
The Old Control Tower
Lavenham Airfield
Old Bury Road, Alpheton
Sudbury, Suffolk, CO10 9BT
Tel: 01284 827472
Email: pl@djgoode.co.uk

Company Reg. No. 4568964

Registered in England & Wales